


Installation

S27-276	S27-368
	
Ball valves prior to June 28, 2019	Ball valves after June 28, 2019


S30-061, S30-062, S30-081, S30-104
Ball Valve/Handle Prepack (Right Handle)

Handles on ball valves prior to June 28, 2019 are not compatible with the new version of ball valves. One of the below listed kits is required to replace the handle.

Shut off water supply before beginning installation.



Ball Valves After June 28, 2019



Old style handle will not fit onto new style ball valves.

Ball Valves Prior to June 28, 2019

	Description	S30-061	S30-104	S30-062	S30-081
1	1" Ball Valve with nut, stainless steel (S27-368)	X		X	X
1.1*	1" Ball Valve with nut, vented, 304 SS (S27-369)		X		
2	Adapter (153-489)	X	X	X	
2.1	Adapter, 316 SS (153-496)				X
3	Washer (24-048)	X	X	X	X
4	Nut (110-264)				
5	Handle (128-202)			X	
5.1	Handle (128-201)	X	X		
5.2	Handle, 316 SS (128-205)				X
6	Handle, Old Style (128-142)				
7	Jam Nut (161-079)				
8	Lockwasher (142-002bc				

*Item used with frost proof applications.

215-1897 Rev. A; ECO 19-05-002F
© 2019 Bradley

P.O. Box 309
Menomonee Falls, WI 53052 USA
800 BRADLEY (800 272 3539)
+1 262 251 6000
bradleycorp.com