APS-300 Series 12/24 Power Supply
9.8VDC-13.7VDC @ 2.8 Amps max / 20.0VDC-27.5VDC @ 1.4 Amps max Power-limited

Features APS-300 Series:

- **Small – Self Contained – Efficient**
- **Universal AC Input 110-240VAC**
- **Operates under Brown Out conditions**
- **9.8VDC-13.7VDC, 2.8A/20.0VDC-27.5VDC, 1.4A Selectable Continuous Duty**
- **Input and Output Surge Protection**
- **Power Limited Output with Thermal Protection**
- **AC and DC LED's**
- **Quality Manufactured in the USA with a lifetime Warranty**
- **Outputs are Power Limited**
- **Provided in Standard Enclosure 14"x 8.5"x 3.5"**
- **Precise Battery Regulation for all sealed Lead Acid Battery(s)**
- **Battery Online, No Drop or Switch Over with AC Power Fail**
- **Reverse Battery Protection**
- **Comes with plug in battery cable assembly**
- **UL and cUL tested to Standards UL 603 Burglar Alarm Power Supplies, UL 294 Access Control Units, and ULC-S318-96 Canadian Standard for Power Supplies for Burglar Alarm Systems**
- **Relay "C" Contacts Indicates AC Power Status**
- **LTW Limited Warning of stand by battery(s)**
- **Battery Disconnect on depleted Battery(s)**



Ordering examples:

APS-300	Supervised Power Supply/Charger module with Standard Enclosure 14" x 8.5" x 3.5"
APS-3004C	APS-300 with one PD-4C, four output PTC protected distribution board
APS-300FT	APS-300 with one PDFT fire relay module



ALARM CONTROLS
ASSA ABLOY
Alarm Controls Corporation
19 Brandywine Drive
Deer Park, NY 11729

ASSA ABLOY, the global leader in door opening solutions

Phone: (800) 645-5538
info@alarmcontrols.com
www.alarmcontrols.com

Description

The APS-300 Series Power Supplies are heavy duty self contained, efficient clean off-line switching power supplies that are selectable between 9.8VDC-13.7VDC at 2.8 Amps, and 20.0VDC-27.5VDC at 1.4 Amps. With the universal AC input, these supplies may be connected anywhere in the world with no plug-in transformer or any alterations. These power supplies have exceptional brown out capability with operation down to 60VAC. The extensive filtering system provides a very clean DC output that can power the most sensitive electronic controls and reader where a linear power supply is recommended. All of the supplies are power limited and thermally protected. All output faults are self restoring.

The APS-300 series have a precision lead acid battery(s) charger that obtains maximum battery life while providing a 9.8VDC-13.7VDC or 20.0VDC-27.5VDC uninterruptible power supply. The APS-300 Series are protected against Battery(s) reversal, shorting or overloading. Before connecting AC and battery(s), set 12V/24V selector jumpers to the desired voltage.

Caution, damage will occur if jumpers are moved with DC output load or Battery connected. Confirm proper voltage before connecting devices.

The APS-300 has the additional supervisory features of a set of form "C" relay contacts that indicates AC power status and a special electronic circuit that limits the output current to provide power limiting and load disconnect when battery is depleted.

Specifications

AC Input: L, N, G - 3P Orange Terminal block

Safety block with recessed hardware insulation that will accept up to 12AWG

L= Line, N= Neutral, and G = Ground

AC Input Rating 110-240VAC/47-63Hz 130W

Note: The Ground connection on the APS-300 is connected to the enclosure with a metal standoff.

AC LED Indicator *(Next to AC Input Terminal)*

The AC indicator is a green LED, which is illuminated when AC is present.

AC Line Primary Fuse

Fuse: GMA-2 5mm x 20mm 2A 250VAC

Replace this fuse only while the equipment is electrically disconnected from the branch-circuit supply. The proper size 2A fuse must be used.

DC VOLTAGE SELECTOR JUMPER J1

The selector jumper J1 selects the voltage to 12 or 24VDC. As marked on the PCB, jumping 1&2 and 3&4 sets the supply to 12V range. Jumping 2&3 sets the supply to the 24V range.

CAUTION To prevent damage, remove DC load and battery(s) connections before switching selector J1 jumpers.

DC OUTPUT: 2P Terminal block

Output voltage Range: 12V/24V
.....9.8VDC-13.7VDC/20.0VDC-27.5VDC

Output voltage typical AC ON 13.65/27.30VDC

Output continuous current 12V/24V 2.8A/1.4A

Current Overload Short Circuit Protection ..... Yes

Thermal runaway Protection ..... Yes

Current Overload and Thermal shutdown will auto-restart without removing load.

Power limiting ..... Yes

Ambient operating temp. range ..... -32°F(0°) to 120^{oF} (49°C)

Storage Temperature ..... -60°F to 190°F

Switching Frequency 132KHz

DC LED Indicator *(Adjacent to DC Output)* ..... Red

Battery Connector: ..... (Header plug marked [–Bat+])

The battery charger is set to charge 12V or 24V sealed or wet lead acid batteries. Two 12V batteries are connected in series for 24V with a provided wire assembly p/n: WA-24SW. A 15" Battery cable assembly p/n: WA-15IBAT is provided that plugs from module battery connector to the battery. Red (+) 12VDC, Black (–) Neg.

Each of the 3 wires listed above that connect to the standby Batteries are covered with special clear tubing that provides additional insulation to ensure proper separation or Power Limited and NON Power Limited wires.

Supports any type of lead acid Battery(s)
..... 12v 4AH-18Ah

UL evaluated with 18Ah on 12V and (2) 9Ah on 24V sealed lead acid battery(s)

Battery(s) PTC self resetting Circuit Breaker .....3A PTC

Battery(s) Reverse hookup protection ..... Yes

To estimate the recharge time in hours for depleted battery(s), multiply the AH rating times 4 (Ah x 4). As an example, a 24V system with two depleted 12v 7Ah batteries would take about 28 hours to re-charge.

APS-300 Supervision features:

DC Output Electronic Power Limited ..... Yes

This feature limits the output current to a maximum peak of 6 Amps to comply with UL Power Limiting requirement.

AC Status Output Relay: 3P Terminal block

AC Fail form "C" contacts rating 2A, 24VDC

Three position AC fail terminal block marked "NO, C, NC" are shown in the Normal, energized, "AC ON" condition.

Using these relay contacts as a switch with a proper DC power source the AC power loss can be locally annunciated as required with Amber or Red Led indicator or sounding device. The contacts may also be used to annunciate, AC failure to a Listed Burglar Alarm or Access Control panel.

Trouble / LTW Limited Time Warning of stand by batteries 95% of Battery has been depleted.

Output, 2 position header .1" spacing **(**+&-**) ..... (**-) sinks 3mA.

The LTW circuit "MUST" be connected either for local or remote annunciation with an Amber or Red LED to indicate DC Trouble or you may annunciate the LTW by connecting the (-) negative open collector output to an appropriate input of a UL Listed Burglar Alarm or Access control panel. When DC Power is normal, the (-) negative output is an open circuit with the LED OFF. When the DC output voltage drops to a point where the standby battery has been 95% depleted, the LTW (-) turns the LED ON to indicate trouble. The LED remains ON after the Stand by battery has been electrically removed from the DC Output.

The Figure LTW Led below shows the hook up on an LED. The following parts (not provided) will be needed to connect the LED to the LTW Header Output.

1 Connector housing .1" spacing with ramp Molex
P/N: 22-01-2021

2 Female connecters for housing Molex
P/N: 08-50-0113

Wire to connect LED connectors are rated for 22-30AWG

Figure LTW LED



Low Battery Disconnect (Battery cut-off)

12v/24v 9.8VDC/VDC/19.6VDC

APS-300 Physical Dimensions

For Indoor Use Only

Module Dimensions ..... 4.84"L x 3.73"W x 2.25"H

Height includes required 5/8" #6 FF Hex aluminum standoffs, not provided with module only.

Mounting Holes Center to Center ..... 4.50"W x 3.41"H

APS-300 Dimensions…….. 14"W x 9"H x 3.5"

APS-300 Weight 6.7Lbs

Standards

RoHS Compliant Lead Free – Not evaluated by UL

UL 603 Power Supplies for Use with Burglar Alarm Systems.

UL 294 Access Control System Units.

ULC-S318-96 Power Supplies for Use with Burglar Alarm Systems.

APS-300 Series Power Supply/Charger Installation Guide

The APS-300 with standby battery(s) provides an uninterruptible 9.8VDC-13.7VDC or 20.0VDC-27.5VDC power source. When use with optional Power Distribution modules PD4C or PDFT, it can provide multiple fused outputs or Fire Interface. The DC output on the APS-300 power supply is Power Limited. This makes all subsequent outputs power limited.

1. The installation of this power supply shall comply with the National Electrical Code (ANSI/NPFA 70), the Canadian Electrical Code, Part 1, and be in accordance with any additional requirements imposed by the local authority having jurisdiction.
2. For use in Indoor Location Only, Mount the Power Supply in desired location. Using the two keyholes on the upper end and the two or three holes along the bottom, mount the enclosure to the wall with appropriate fasteners.
3. Select output voltage by shifting the jumper J1 for 12VDC or 24VDC. **Only change output voltage when AC is OFF and Batteries are not connected**. The APS-300 Series has a continuous output rating of 9.8VDC-13.7VDC at 2.8 Amps or 20.0VDC-27.5VDC at 1.4 Amps. If a power distribution product is used, the total current draw of these devices must be subtracted from the available current rating. See selection table below or individual data sheets. Connect AC Line voltage, 110-240VAC with Earth Ground to the Orange AC input Terminal block. This wiring must be run in separate metal enclosed wiring system only. Note, Ensure all wiring is of appropriate gauge for device being powered. **All Power Limited circuits must be separated by a minimum of .25" from Non-power Limited circuits.**
4. Connect DC devices to the Output Terminals. Observe polarity. On the distribution boards Negative is identified with a (-) or (COM). The Positive is identified with (+) or (HOT). Exit the DC wiring out any of the other available knock outs keeping all the low voltage wiring away from the high voltage wiring and battery leads.
5. If supervision is desired, connect N/C Tamper switch and AC fail form "C" contacts to Security system for annunciation.
6. Add the current draw of the distribution boards to your load calculation to ensure your power requirements are within the unit's continuous power rating. Always check the spec sheet; but as a rule, each LED draws 6mA and each relay draws 20mA.
7. Confirm with Amp meter that your total continuous current conforms to the output current rating and that each output rating is proper for the powered device(s).
8. Connect AC fail contacts to annunciate AC Status condition.
9. Connect appropriate standby battery(s). Remove AC and confirm battery output to test standby battery(s). Mark installation date on Battery with permanent marker.
10. Each protected output on the optional power distribution board PD4C has a Green Status LED. Green ON indicates ready.
11. To reset a tripped PTC Circuit Breaker, you may have to turn power off on outputs, or remove faulted circuit output for up to 2 minutes. This allows the PTC re-settable circuit breaker to cool and reset to its normal "ON" condition.
12. For installation and use of optional PD4C and PDFT, see separate enclosed instructions.

CAUTION: Replace fuses as marked

When calculated your total DC current be sure to add the current of any distributions options you are using. Be sure your normal continuous DC current draw does not exceed the marked rating of the supply.

Select 12/24 J1 only with AC off and Batteries disconnected.

Battery Selection

The table below shows typical standby time in hours for various loads and batteries. The table works for either 12V or 24V batteries. The APS-300 has been evaluated by UL with an 18Ah sealed lead acid battery for 12V and (2) - 9AH batteries for 24V to meet the 4 hour stand by requirement.

Note: UL requires a minimum of 4 hours of standby time for Commercial Mercantile Burglar Alarm. The table below has the required battery size highlighted (*) to provide this 4-hr stand by time under a full rated load.

Approximate Battery Standby Time Table with a reserve of 3 Amps for 5 minutes for Alarm

AH = Amp Hours Capacity at a 20 hour rate - Hrs = Hours

Total Output Amps	4Ah Battery Standby	7Ah Battery Standby	9Ah Battery Standby	18Ah Battery Standby	24Ah Standby
1A	2.92 Hrs	5.32 Hrs	7.79 Hrs	15.89 Hrs	23.65 Hrs
1.4A*	2.09 Hrs	4.75 Hrs	5.56 Hrs*	12.61 Hrs	16.89 Hrs
2A	1.46 Hrs	1.3 Hrs	3.46 Hrs	7.94Hrs	10.64 Hrs
2.8A*	1.04 Hrs	1.9 Hrs	2.47 Hrs	5.04 Hrs*	7.60 Hrs

The Battery recharge time is 2.6 hours for each 1 Ah Amp Hour of battery capacity with either 12V or 24V batteries. The minimum battery capacity is 4Ah and the practical limit is 24Ah UL evaluated with an 18Ah battery on the 12V configuration and (2) 9Ah batteries on the 24V configuration. Please see the Figures for 12V configurations and 24V configurations below in this document. UL Listed systems require that if standby batteries are to be used they must have a 4 hour capacity under the full rated load.

Recommended Maintenance

The power supply and stand by battery(s) should be tested at least once a year as follows:

1. Check LED's for normal state. AC ON Green and DC ON Red.
2. Check output voltage with normal load. With AC ON for 12V setting, DC output voltage should read between 12.83VDC-13.69VDC and 27.1 - 27.4VDC on the 24V setting.
3. Check DC Output Amps to be sure it complies with output rating.
4. Disconnect AC input. AC LED should be off, and the DC LED's should remain normal.
5. Check DC Output to be above 11.5VDC for 12v setting and 23.0VDC for 24V setting. This checks standby batteries to be operational. Sealed lead acid batteries have a typical life of 3 to 5 years. Test battery by itself as outlined in your battery instructions to be sure the Amp hour capacity is within proper range.
6. Re Apply AC and verify AC LED ON.


RIGHT SIDE
3.50
9.18
3.24
0.90
0.90
1.06
1/2" 3/4 Knock Out
1/2" Knock Out (2)
Tab
4.08
2.55
1/2 3/4 Knock Out
13.94
6.50
1" Knock Out
1.06
1.26
3.50
1.10
.185
TAMPER SWITCH
Lock Tab
0.60
1.10
2.90
1.375 Knock Out (3)
8 #6-32 studs for module mounting
Model: APS300
Note: AC FAIL, DC OUT, Tamper=Power Limited
AC IN, Battery = Non Power Limited
110-240VAC Input
(no power-limited)
separate metal conduit
keep a minimum
space of 1/4 inch
between power
limited wiring.
AC metal Conduit
1.10
0.60
1.06
1.26
1/2 3/4 Knock Out
BACK EDGE
6.50
1" Knock Out
COVER HINGE
1.26
3.50
LEFT SIDE
3.50
1/2 3/4 Knock Out
1/2" KNOCK OUT
0.90
3.24
9.18